

NEWS from CPSC

U.S. Consumer Product Safety Commission

Office of Information and Public Affairs

Washington, DC 20207

FOR IMMEDIATE RELEASE

December 19, 2006

Release #07-063

Firm's Recall Hotline: (877) 597-3321

Firm's Media Contact: Yale Steingard (215) 535-8900

CPSC Recall Hotline: (800) 638-2772

CPSC Media Contact: (301) 504-7908

Crown Boiler Co. Recalls Boilers Due to Carbon Monoxide Poisoning Hazard

WASHINGTON, D.C. - The U.S. Consumer Product Safety Commission, in cooperation with the firm named below, today announced a voluntary recall of the following consumer product. Consumers should stop using recalled products immediately unless otherwise instructed.

Name of Product: Bermuda BSI and Cayman CWI Series Gas Boilers

Units: About 400

Manufacturer: Crown Boiler Co., of Philadelphia, Pa.

Hazard: The boilers can generate excessive levels of carbon monoxide (CO) in the flue gases, posing a risk of CO poisoning.

Incidents/Injuries: Crown Boiler has received one report of high levels of carbon monoxide from these boilers. No injuries have been reported.

Description: The recall involves Bermuda BSI and Cayman CWI Series gas-fired boilers designed for indoor installation. Model and serial numbers included in this recall are listed below and are located on the rating plate. The boilers have a two-tone, red and gray jacket enclosure with the controls and piping on the right side of the unit. The rating plate is a silver label located in the upper left hand corner of the right side panel.

Model Numbers	Serial Numbers
BSI069SN	CROWNB000304258 and CROWNB000411446
BSI069EN	
BSI172SL	
BSI172EL	
CWI069SN	
CWI069EN	
CWI172SL	
CWI172EL	

Sold by: Plumbing and heating wholesale distributors to plumbers and contractors nationwide from October 2002 through October 2006 for between \$800 and \$2,100.

Manufactured in: United States

Remedy: Consumers who have not already been contacted by their contractor should immediately contact their installer or Crown Boiler Co. to arrange for a free repair. Consumers are reminded to install a CO alarm outside all sleeping areas, or make sure their current CO alarms have working batteries.

Consumer Contact: For more information, contact Crown Boiler Co toll-free at (877) 597-3321 between 8 a.m. and 5 p.m. ET Monday through Friday, or visit the firm's Web site at www.crownboiler.com



Recalled Bermuda BSI Series
Gas Boiler

Cayman CWI Series Gas Boiler



[Send the link for this page to a friend!](#) The U.S. Consumer Product Safety Commission is charged with protecting the public from unreasonable risks of serious injury or death from more than 15,000 types of consumer products under the agency's jurisdiction. Deaths, injuries and property damage from consumer product incidents cost the nation more than \$700 billion annually. The CPSC is committed to protecting consumers and families from products that pose a fire, electrical, chemical, or mechanical hazard or can injure children. The CPSC's work to ensure the safety of consumer products - such as toys, cribs, power tools, cigarette lighters, and household chemicals - contributed significantly to the 30 percent decline in the rate of deaths and injuries associated with consumer products over the past 30 years.

To report a dangerous product or a product-related injury, call CPSC's hotline at (800) 638-2772 or CPSC's teletypewriter at (800) 638-8270, or visit CPSC's web site at www.cpsc.gov/talk.html. To join a CPSC email subscription list, please go to www.cpsc.gov/cpsclist.asp. Consumers can obtain this release and recall information at CPSC's Web site at www.cpsc.gov.